

CERTIFICATE OF COMPLIANCE

Certificate Number 20170510 – MH26965
Report Reference MH26965 – 20031027
Issue Date 2017-MAY-10

Issued to: PRODUITS DE VENTILATION H C E INC
6150 BOUL DES GRANDES PRAIRIES
ST LEONARD, QC H1P 1A2 CANADA

**This is to certify that
representative samples of**

Exhaust Hoods Without Exhaust Dampers
USL, CNL - Exhaust hoods with exhaust dampers for
restaurant-type cooking: Models HAI and HAB with optional
prefixes and suffixes (see General Character and Use).
Hood lengths range from 0.9 m - 4.88 m (3 feet to 16 feet).

USL, CNL - Exhaust hoods without exhaust dampers for
restaurant-type cooking: Models HAI and HAB with optional
prefixes and suffixes (see General Character and Use).
Hood lengths range from 0.9 m - 4.88 m (3 feet to 16 feet).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 710, "Exhaust Hoods for Commercial Cooking
Equipment" and CAN/ULC-S646, "Exhaust Hoods and
Related Controls for Commercial and Institutional Cooking
Equipment."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

